

Works Certificate

in accordance with DIN EN 10204: 2005-01



A Phoenix Mecano Company

Impact Test according to IEC 62262: 2002-02

Cerificat-No.: 688

Test-No.: 1072

Date: 18.08.2016

by order of: Bopla Gehäuse Systeme GmbH

test items

item number:

Product group: 96

Bocube in PC-V0: *1) *2)

B 080805, B 100804, B 100806, B 100809, B 140804, B 140806,
B 140809, B 141306, B 141309, B 180806, B 180809, B 181304,
B 181306, B 181309, B 221304, B 221306, B 221309, B 261306,
B 261704, B 261706, B 261709, B 261712, B 233012, B 233016,
B 273612, B 273616

form of testing / result:

IK 07 in combination with IP 66 *1) *2) / IP 68 - 1,2m (2 hours) *1) / IP 67 *2)

test passed

remarks: *1) Color in RAL 7024 and RAL 7035

*1) also with crystal-clear lid (version: PC-V0-G)

*2) optional with hand operated hinge

ATTENTION: Ingress protection for the hand operated hinge only with
closed quick-release catches !

NOTE: With regard to electrical safety, the HB hinge is not suitable
without additional measures (protective barrier in the housing) !

Test executed by:

26.01.2023

P. Hemeier

controlled:

26.01.2023

A. Krömer

use: internal: external:

Attachment: